

October 27, 2015

Walker Zanger's Tuileries Ceramic Tile Collection - ASTM C 373-Water Absorption Test Values

Please note that our Tuileries Ceramic Tile Collection has an ASTM C 373 test value of 14.05%.

ANSI A137.1 - Wall Tile: Classified as "Non-Vitreous Tile" Class P4 and Water Absorption shall be Minimum 7.0% & Maximum of 20.0%. Therefore, the Walker Zanger Tuileries Ceramic Tile Collection is Compliant with ASTM C 373.

Bob Buswell



Technical Director
bbuswell@walkerzanger.com